Certificate

Certified Passive House component

For cool temperate climates, valid until 31 December 2017

Entry door with glazing Category:

Manufacturer: Ekstrands Dörrar och Fönster AB

28350 Osby,

Sweden

Passiv 91 with glass Product:

This certificate was awarded based on the following criteria for the cool, temperate climate zone:

Heat losses:

U-value of the door (1.10 m wide by 2.20 m tall):

 $U_D = 0.77 \text{ W/(m}^2\text{K}) \le 0.80 \text{ W/(m}^2\text{K})$

 $U_{D,installed} \leq 0.85 \text{ W/(m}^2\text{K)}$

Provided that the installation is carried out according to the certification report, available from the manufacturer.

The U-values were calculated based on glazing with U_g = 0.53 W/(m²K) in accordance with EN 673 and the spacer Chromatech Ultra F. Glass size: 0.65 m x 1.49 m

Airtightness:

Airtightness class 4 according to EN 12207.

The airtightness criterion has been met.

The airtightness test according to EN 1026 was carried out taking into account a maximum deformation of the door leaf, as per EN 1121.

Dr. Wolfgang Feist 64283 Darmstadt Germany





